

# Surge Protective Devices

## UL 1449

### 1 Scope

1.1 These requirements cover Surge Protective Devices (SPDs) designed for repeated limiting of transient voltage surges as specified in the standard on 50 or 60 Hz power circuits not exceeding 1000 V and designated as follows:

Type 1 - Permanently connected SPDs intended for installation between the secondary of the service transformer and the line side of the service equipment overcurrent device, as well as the load side, including watt-hour meter socket enclosures and intended to be installed without an external overcurrent protective device..

Type 2 - Permanently connected SPDs intended for installation on the load side of the service equipment overcurrent device; including SPDs located at the branch panel.

Type 3 - Point of utilization SPDs, installed at a minimum conductor length of 10 meters (30 feet) from the electrical service panel to the point of utilization, for example cord connected, direct plug-in, receptacle type and SPDs installed at the utilization equipment being protected. See marking in 64.2. The distance (10 meters) is exclusive of conductors provided with or used to attach SPDs.

Type 4 - Component SPDs, including discrete components as well as component assemblies.

Section 1 effective September 29, 2009

1.2 Except as indicated in 1.3, the products covered by this Standard are rated and intended for connection to circuits or supply sources having nominal voltage ratings as specified in Table 39.1.

1.3 A product intended for connection to an ac circuit or supply source other than that specified in 1.2 may be examined and tested in accordance with the intent of the requirements in this standard and, if found to be substantially equivalent, may be judged to comply with this Standard.

1.4 These requirements cover cord-connected and direct plug-in SPDs intended for indoor use and permanently connected SPDs intended for indoor and outdoor use in accordance with the National Electrical Code, ANSI/NFPA-70.

1.5 These requirements do not cover the interconnection of multiple field installed SPDs.

1.6 These requirements cover SPDs that may include components specifically intended to function as filters for conducted electromagnetic interference (EMI) or noise, in addition to limiting transient voltage surges.

1.7 These requirements cover SPDs employing circuit components intended to provide secondary protection for telephone communication circuits and circuit components intended to protect data communication or fire alarm circuits.

1.8 These requirements cover SPDs employing antenna connections for audio-video products.

1.9 An SPD that has a battery backup feature or other uninterruptible power supply equipment shall also comply with the applicable requirements in the Standard for Uninterruptible Power Supply Equipment, UL 1778.

1.10 These requirements cover SPDs/Panelboard Extension Modules. These products shall also comply with Standard for Panelboards, UL 67.

1.11 These requirements do not evaluate the effect of SPDs on connected loads, the effect of SPDs on harmonic distortion of the supply voltage, the degree of attenuation provided by SPDs, nor the adequacy of the voltage protection rating of SPDs to protect specific connected equipment from upset or damage.

1.12 This standard does not cover cord connected or direct plug-in SPDs intended for use with medical equipment. Medical equipment is typically intended for use in General Patient Care Areas or Critical Patient Care Areas as defined by Article 517 of the National Electrical Code for Health Care Facilities. SPDs intended for such use shall comply with the requirements of the Standard for Safety of Medical Electrical Equipment, Part 1: General Requirements, UL 60601-1, and the Standard for Safety Requirements for Medical Electrical Systems, IEC 60601-1-1.

1.13 An SPD intended to serve as an outlet cover plate or outlet box hood shall comply with the requirement for faceplates in the Standard for Cover Plates for Flush Mounted Wiring Devices, UL 514D.

---

UL 1449 references these Standards: [20](#) \* [44](#) \* [50](#) \* [62](#) \* [67](#) \* [83](#) \* [94](#) \* [224](#) \* [248-1](#) \* [248-4](#) \* [248-8](#) \* [248-10](#) \* [248-12](#) \* [248-14](#) \* [248-15](#) \* [248-16](#) \* [248](#) \* [310](#) \* [414](#) \* [452](#) \* [486A-486B](#) \* [489](#) \* [496](#) \* [497A](#) \* [497B](#) \* [498](#) \* [510](#) \* [512](#) \* [514A](#) \* [514B](#) \* [514C](#) \* [514D](#) \* [746A](#) \* [746B](#) \* [746C](#) \* [746D](#) \* [746E](#) \* [796](#) \* [810](#) \* [817](#) \* [840](#) \* [969](#) \* [991](#) \* [1054](#) \* [1059](#) \* [1077](#) \* [1283](#) \* [1310](#) \* [1363](#) \* [1414](#) \* [1441](#) \* [1446](#) \* [1492](#) \* [1557](#) \* [1577](#) \* [1581](#) \* [1585](#) \* [1681](#) \* [1778](#) \* [60601-1](#) \* [60691](#) \* [60950-1](#) \* [61058-1](#) \* .

[Table of Contents](#) for UL 1449.

[Purchase UL Standards](#)

[UL Standards InfoNet](#)

[UL Standards Catalog](#)